

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20190515-S24913  
**Report Reference** S24913-20100318  
**Issue Date** 2019-MAY-15

**Issued to:** LGM PRODUCTS LTD  
RIVERSIDE INDUSTRIAL PARK, UNIT 15  
FARNHAM, SURREY GU9 7UG UNITED KINGDOM

**This certificate confirms that  
representative samples of**

HEAT-ACTUATED DEVICES FOR SPECIAL  
APPLICATION; HEAT-AUTOMATIC FIRE DETECTORS  
Fixed temperature line type heat detector cables for  
indoor/outdoor use: FT68, FT88, FT105, FT-185-R,  
FT-230-X, FT68-R, FT88-R, FT105-R

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.


**Standard(s) for Safety:** UL521, Heat Detectors for Fire Protective Signaling  
Systems  
ULC S530, Heat Actuated Fire Detectors for Fire Alarm  
Systems

**Additional Information:** See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

